

Evidence of Performance

Resistance to wind load
Watertightness
Air permeability

Test Report 11-000413-PB01-A01-02-en-01



Client **Aluplast - Belac**
Kamenovacki put bb

12300 Petrovac
Serbia

Basis

EN 14351-1:2006+A1:2010

Test standards:

EN 1026 : 2000-06

EN 1027 : 2000-06

EN 12211 : 2000-06

EN 12046-1 : 2003-11

EN 14609 : 2004-03

Corresponds to the national standard. (DIN EN)

Product	Tilt and turn window
System	Aluplast Ideal 6000
Overall dimensions (W x H)	1,228 mm x 1,476 mm
Frame material	PVC/U white
Special features	-/-

Representation



Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1 shall be observed.

Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

Notes on publication

The **ift**-Guidance Sheet "Conditions and Guidance for the Use of **ift** Test Documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 11 pages.

Resistance to wind load – EN 12210



Class C4 / B4

Watertightness – EN 12208



Class E750

Air permeability – EN 12207



Class 4

ift Rosenheim
29. Juni 2011


Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
Building Components


Robert Kolacny, Dipl.-Ing. (FH)
Operating Product Officer
Building Components



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkante PUZ-Stelle: BAY 18
 
DAP-PL-0908 99
DAP-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-60